

PROVIDE ADDRESS NUMBERING WHICH IS VISIBLE FROM STREETCODE SECTIONS

2010 Yocha Dehe Fire Code

Section 505.1 Premises identification. Approved numbers or addresses shall be placed prior to occupying on all new and existing buildings as to be plainly visible and legible from the street or road fronting the property. Said numbers shall contrast with their background. In setting requirements for addressing, the Chief may be guided by the standard published by the County of Sacramento Building Inspection Division, "Posting of Building Addresses". **(WITH THE USE OF Sacto Co Public Works Stds....do you want to use these????)**

EXPLANATION

All buildings are required to post its address. Addresses should be visible from the street which fronts the building. This street may be the public street for which the address is given or it may be the private roadway that fronts the building and allows access to the building. Visible is defined by our ability to see and read the numbers from the street. The building address numbering shall be on a contrasting background.

Another consideration is the location of the numbers. Numbering shall not be obstructed by trees, exterior walls or any other obstruction which would hinder the view of the numbers. If an obstruction is present, it shall either be removed or the numbering relocated to a visible location.

In buildings with multiple suites or businesses, the individual suites or businesses shall also be clearly identified, usually by placing the suite number over or on the main entry/exit door. These addresses shall also be clearly visible and be of a contrasting color. Any other doors providing access to the suite or business should also be marked in the same manner.

RATIONALE

In order to facilitate rapid response to an emergency at your business/building, addresses need to be clearly visible to the fire apparatus from the street. If we cannot easily identify your address, valuable time could be lost trying to locate your business.

Date: January 1, 2011

