

## MAINTAIN WIRING IN GOOD CONDITION AND PROTECT FROM DAMAGE

### CODE SECTIONS

*2010 Yocha Dehe Fire Code*

**Section 605.1 Abatement of electrical hazards.** Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

### EXPLANATION

All electrical wiring shall be installed, maintained in good condition, and protected from damage in accordance with the Electrical Code. Any frayed wires, undersized wires, and illegally or improperly installed wiring shall be corrected.

### RATIONALE

Improperly installed, poorly maintained, and damaged wires pose a significant fire risk to your building. Electrical systems must be installed and maintained per the Electrical Code to minimize fire potential in your building.

Date: January 1, 2011

Page 1 of 1